

## 521 Visit Compliance Report

**Licensee:** Perimeter Behavioral of Forrest City  
**Licensee Address:** 603 KITTLE ROAD FORREST CITY, AR 72335  
**Licensing Specialist:** Lakesha White **Person In Charge:** N/A  
**Monitor Visit Date:** 3/3/2021  
**Purpose of Visit:** Psychiatric Residential Buildings and Grounds

**Regulations Out of Compliance:**

| Regulation | Serious Violation | Discussion/Observation   | Due Date  | Correction Date | Corrected On Site |
|------------|-------------------|--|-----------|-----------------|-------------------|
| R911.6     | No                | The sprinklers will need to be covered in rooms: 105, 106, 107, 206, 305, 307, 308, 405<br>The sprinklers will need to be covered and air conditioners screen tightened or replaced in rooms 301, 302, 303, 402, 403, 406, 408 and 407<br>Repair the door in room 209<br>Need fire extinguisher on SRP hall due to construction on the doors and no access to the nursing station where the extinguisher is located<br>Repair missing tiles in rooms 202 and 206 | 3/10/2021 |                 | No                |

**Regulations Needing Technical Assistance:**

No regulations needing technical assistance.

**Regulations Not Correctable:**

No regulations marked as not correctable.

**Narrative:**

No narrative on file for this monitor visit.

## 521 Visit Compliance Report

**Licensee:** Perimeter Behavioral of Forrest City  
**Licensee Address:** 603 KITTLE ROAD FORREST CITY, AR 72335  
**Licensing Specialist:** Lakesha White      **Person In Charge:** N/A  
**Monitor Visit Date:** 3/3/2021  
**Purpose of Visit:** Background Check Review

**Regulations Out of Compliance:**

No regulations out of compliance.

**Regulations Needing Technical Assistance:**

No regulations needing technical assistance.

**Regulations Not Correctable:**

No regulations marked as not correctable.

**Narrative:**

Reviewed background checks for 3 staff:

Ilesha Rolfe DOH 2/22/21  
James Rice DOH 2/22/21  
Antinika Logan DOH 2/22/21

-no violations-