Arkansas Department of Human Services
Division of Child Care and Early Childhood Education
P.O. Box 1437, Slot S140 - Little Rock, AR 72203-1437
501-682-8590 - Fax: 501-683-6060 - TDD: 501-682-1550

521 Visit Compliance Report

Licensee: Centers for Youth and Families Youth Emergency Shelter

Licensee Address: 6425 WEST 12TH STREET LITTLE ROCK, AR 72204

Licensing Specialist: Steven Pitts **Person In Charge:** Cookie Higgins

Monitor Visit Date: 8/12/2021

Purpose of Visit: Psychiatric Residential Buildings and Grounds

Regulations Out of Compliance:

Regulation	Serious Violation	Discussion/Observation	Due Date	Correction Date	Corrected On Site
R912.4	No	CCSS Pitts viewed fecal matter and tissue in toilet on the boys hall. Ensure that the bathrooms in the facility are clean and sanitary. Corrected during the visit.	8/12/2021	8/12/2021	No

Regulations Needing Technical Assistance:

Regulation	Discussion/Observation
R911.15	CCSS Pitts viewed a possible issue in reference to suicide risk regarding the sprinkler heads throughout the facility and the door knobs in the classroom not being anti-ligature. Technical Assistance was provided.

Regulations Not Correctable:

No regulations marked as not correctable.

Narrative:

On 8/12/21, from 1:00 p.m. to 3;00 p.m.. I conducted a Building and Grounds Inspection Visit at Destiny House on Center's For Youth and Family Campus in Little Rock. All previous issue requiring technical assistance have been fixed. All faucets and showers are currently operational in the facility. The current census of the building is 8. Staff ratios were good at the time of the visit. CCSS Pitts viewed a the boys bathroom in need of cleaning (tissue and fecal matter viewed). The bathroom was cleaned and this corrected on cite. Technical Assistance provided regarding the door knobs in the classroom not being anti ligature and the sprinkler head in the facility not being recessed.