CFS - Command Log

Printed on March 15, 2023

CFS#

CFS2303235

Call Taker

KILEY HOWTON

Location

1521 ALBERT ST, FORREST CITY, AR 72335 (Woodridge Behavioral Center)

Location Details

Primary Incident Code ALRF: Fire Alarm Mod

Emergency Fire/Medical

Priority

Use Caution

No

Primary Disposition

Handled By Officer / Deputy

Beat

Zone **Call Time** Madison Police Department 01/28/23 09:30:15

Completed Time

01/28/23 09:43:05

Reporters

OLD ARKANSAS ALARMS (Initial Reporter)

Sex DOB Address

Report Time

01/28/23 09:30:15

How Reported Phone

From Phone

Contact Phone (866) 858-8950

Comments

Other Names

Vehicles

Responders

CALL1

FCBAT1 FCE1

FCFD, Battalion Chief FCFD, Engine CO 1

FCFD (Primary) FCFD (Primary) FCFD (Primary)

FCE2 (Primary)

FCFD, Engine Co 2

FCFD (Primary)

543 (Primary)

543 - MITLEFF, DALTON

FCPD

Response Times

Assigned 01/28/23 09:31:46 01/28/23 09:32:40

Enroute Arrived

01/28/23 09:34:19

Leaving **Arrived At**

Completed 01/28/23 09:43:05

IR / External Agency Numbers

FCFD 202300100

Officer Addenda

Command Log Filter: All Commands | Details: Hidden | Units: All Units | Revised Entries: Shown

01/28/23 09:30:15 | HOWTON, KILEY | New CFS 01/28/23 09:31:46 | HOWTON, KILEY | CALL1 | Assign 01/28/23 09:32:02 | HOWTON, KILEY | 543 | Assign 01/28/23 09:32:40 | FCFD, Engine Co 2 | FCE2 | Enroute 01/28/23 09:33:20 | FCFD, Battalion Chief | FCBAT1 | Enroute 01/28/23 09:33:25 | HOWTON, KILEY | MOTION IS ROOM 301 SMOKE DETECTOR 01/28/23 09:34:19 | LAWS, ALLISON | 543 | On Scene 01/28/23 09:36:33 | FCFD, Battalion Chief | FCBAT1 | On Scene 01/28/23 09:37:12 | FCFD, Engine CO 1 | FCE1 | On Scene 01/28/23 09:37:41 | FCFD, Engine Co 2 | FCE2 | Available 01/28/23 09:42:06 | HOWTON, KILEY | 543 | Available - ADVISED EVERYTHING 104-01/28/23 09:42:14 | HOWTON, KILEY | 10-4 01/28/23 09:42:28 | FCFD, Battalion Chief | FCBAT1 | Message - smoke detector is broken, maintenance is on scene to get it repaired or call alarm company if its beyond their skill. 01/28/23 09:42:39 | FCFD, Battalion Chief | FCBAT1 | Available 01/28/23 09:43:05 | HOWTON, KILEY | CALL1, FCE1 | Complete

CLQ

Requested At Sent To Status Received At Location Accuracy CFS#

CFS2303235

Call Taker

KILEY HOWTON

Location

1521 ALBERT ST, FORREST CITY, AR 72335 (Woodridge Behavioral Center)

Location Details

Primary Incident Code ALRF: Fire Alarm

Emergency Fire/Medical

Mod **Priority**

Use Caution

No

Primary Disposition

Handled By Officer / Deputy

Beat Zone

Madison Police Department

Call Time

01/28/23 09:30:15

Completed Time

01/28/23 09:43:05

Reporters

OLD ARKANSAS ALARMS (Initial Reporter)

Sex DOB Address

Report Time

01/28/23 09:30:15

How Reported Phone

From Phone

Contact Phone (866) 858-8950

Comments

Other Names

Vehicles

Responders

CALL1

FCBAT1

FCE1 FCE2 (Primary) 543 (Primary)

FCFD, Battalion Chief

FCFD, Engine CO 1 FCFD, Engine Co 2

543 - MITLEFF, DALTON

FCFD (Primary) FCFD (Primary)

FCFD (Primary) **FCPD**

FCFD (Primary)

Response Times

Assigned

01/28/23 09:31:46

Enroute Arrived

01/28/23 09:32:40 01/28/23 09:34:19

Leaving Arrived At

Completed 01/28/23 09:43:05

IR / External Agency Numbers

FCFD 202300100

Officer Addenda

Unit Response Times

Non Unit Specific Times	
01/28/23 09:30:15 New CFS	_
01/28/23 09:33:25 MOTION IS ROOM 301 SMOKE DETECTOR	
01/28/23 09:42:14 10-4	
543	
01/28/23 09:32:02 Assign	_
01/28/23 09:34:19 On Scene	
01/28/23 09:42:06 Available - ADVISED EVERYTHING 104-	
CALL1	
01/28/23 09:31:46 Assign	_
CALL1, FCE1	
01/28/23 09:43:05 Complete	
FCBAT1	
01/28/23 09:33:20 Enroute	_
01/28/23 09:36:33 On Scene	
01/28/23 09:42:28 Message - smoke detector is broken, maintenance is on scene to get it repaired or call alarm	
company it its beyond their skill.	
01/28/23 09:42:39 Available	
FCE1	
01/28/23 09:37:12 On Scene	
FCE2	
01/28/23 09:32:40 Enroute	_
01/28/23 09:37:41 Available	